

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

**8080a-b-c-E1-d. Series Indicators and Transmitters.**

XP/II/1/BCD/T6; DIP/II,III/1/EFG/T6; Type 4X.

a = Model FR, KN, MN, PN, PP, PR or RR.

b = Enclosure material A or T.

c = Conduit entry and process connection 01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 16 or 17.

d = Accessories MM, NR, PM or RC.

### Equipment Ratings:

Explosionproof for use in Class I, Division 1, Groups B, C and D and Dust-Ignitionproof for Class II/III, Division 1, Groups E, F and G hazardous (classified) locations, indoor and outdoor (Type 4X).

### FM Approved for:

International Metal Engineering Pte Ltd  
Singapore 319261

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3615	2006
Class 3810	2005
ANSI/NEMA 250	1991
ANSI/IEC 60529	2004

Original Project ID: 3031359

Approval Granted: *January 29, 2008*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

*Robert L. Martell, Jr.*  
 \_\_\_\_\_  
 Robert L. Martell, Jr.  
 Assistant Vice President

*January 29, 2008*  
 \_\_\_\_\_  
 Date