



Certificate of Compliance

Certificate: 1952640 (LR22921)

Master Contract: 167207

Project: 2049991

Date Issued: 2008/12/24

Issued to: Custom Control Sensors Incorporated

21111 Plummer St
Chatsworth, CA 91311
USA

Attention: Mr. Jon Dregne

The products listed below are eligible to bear the CSA Mark shown



Issued by: Joe da Silva, C.E.T.

Authorized by: Patricia Pasemko, Operations
Manager

PRODUCTS

CLASS 6248 01 - SWITCHES - Snap - For Hazardous Locations

Class I, Groups A, B, C and D; Class II, Groups E, F and G:

Pressure switches, Dual seal, series 646 and 6900 with suffixes to denote various construction and options, MWP 3000 psi.

Note – Electrical rating will be dependent on what (submitter supplied) CSA certified snap switch assembly is used.



Certificate: 1952640 (LR22921)

Master Contract: 167207

Project: 2049991

Date Issued: 2008/12/24

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 0-M91 (R2001) - General Requirements - Canadian Electrical Code, Part II

CSA Std C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

CSA Std C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CSA Std C22.2 No. 55-M1986 - Special Use Switches

ANSI/ISA-12.27.01-2003 – Requirements for Process Sealing Between Electrical Systems and Flammable or Combustible Process Fluids

MARKINGS

- Manufacturer's name
- Model number
- Maximum working pressure
- "Dual Seal" designation
- CSA Monogram

(Note – All marking information pertaining to use and hazardous location designation as well as electrical rating appear on the CSA certified sealed switch assembly (certified under LR22921 (M/C 167207) that is used.)



Supplement to Certificate of Compliance

Certificate: 1952640

Master Contract: 167207

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2049991	2008/12/24	Update to include Dual Seal Marking and certification of pressure switch series 646
1952640	2008/04/15	Certification of pressure switch series 6900*E*